

FORM J
FIRE FLOW CALCULATIONS SHEET

Calculations based on "Guide for Determination of Fire flow" (1999) prepared by Fire Underwriter's Survey

Civic Address of Property:

1. Type(s) of Construction: _____
 Co-efficient (c) based on type of construction: _____
 Ground Floor Area: _____ m² Number of Stories: _____
 Total Floor Areas: _____ m²
 Fire Flow from Formula ($F = 220 C\sqrt{A}$): _____ LPM (a)

2. Type of Occupancy: _____ Hazard: Low _____ High _____ Other _____
 Hazard Allowance: Add or Subtract: _____ % x (a) = _____ LPM
 Sub Total: _____ LPM (b)

3. Automatic Sprinklers: Yes _____ No _____
 Sprinkler Allowance: Subtract: _____ % x (a) = _____ LPM (c)
 Sub Total: _____ LPM (d)

4. Exposures: Distance / Hazard

| | |
|----------------|-------------|
| 1. Front _____ | Add _____ % |
| 2. Left _____ | Add _____ % |
| 3. Rear _____ | Add _____ % |
| 4. Right _____ | Add _____ % |

Exposure Allowance: Add _____ (e) % x (b) = _____ LPM (f)

TOTAL FIRE FLOW REQUIRED: _____ LPM (g)

SPRINKLER SYSTEM INFORMATION

- (a) If building has automatic sprinklers:
 Distance from sprinkler fire connections at building to nearest available fire hydrant on an unobstructed route: _____ m.

 Will sprinkler system be wet or dry: Wet _____ Dry _____
 If wet, will system contain anti-freeze or any other chemical additive? Yes _____ No _____

 Backflow protection (describe): _____

- (b) If building has no automatic sprinklers:
 Distance from main building entrance to nearest available fire hydrant on an unobstructed route _____ m.

BUILDING CLASSIFICATION PART 3 PART 9 **Professional Seal**

Calculations by: _____ **Date:** _____