

FORM J FIRE FLOW CALCULATIONS SHEET

Calculations based on "Water Supply for Public Fire Protection: A Guide to Recommended Practice in Canada" prepared by Fire Underwriter's Survey.

Civic Address of Property:

1. Type(s) of Construction: _____
Co-efficient (c) based on type of construction: _____
Ground Floor Area: _____ m² Number of Stories: _____
Total Floor Areas(A): _____ m²
Fire Flow from Formula ($F = 220 \text{ CV } A$): _____ L/min (**B**)
2. Type of Occupancy: _____ Hazard: Low _____ High _____ Other _____
Hazard Allowance: Add or Subtract: _____ % x (**B**) = _____ L/min (**C**)
3. Automatic Sprinklers: Yes _____ No _____
Sprinkler Allowance: Subtract: _____ % x (**B**) = _____ L/min (**D**)
4. Exposures: Distance / Hazard
 1. North mAdd _____ %
 2. East _____ m Add _____ %
 3. South mAdd _____ %
 4. West _____ m Add _____ %
 Exposure Allowance: (**B**) X _____ % = _____ L/min (**E**)

TOTAL FIRE FLOW REQUIRED (B+C+D+E): _____ L/min

SPRINKLER SYSTEM INFORMATION

- (a) If building has automatic sprinklers:
Distance from sprinkler fire connections at building to
nearest available fire hydrant on an unobstructed route: _____ m.

Will sprinkler system be wet or dry: Wet _____ Dry _____
If wet, will system contain anti-freeze or any other chemical additive? Yes _____ No _____
Backflow protection (describe): _____

Professional Seal

- (b) If building has no automatic sprinklers:
Distance from main building entrance to nearest available fire hydrant on an unobstructed route _____ m.

Calculations by: _____ **Date:** _____